




520 South Main Street, Suite 2531
Akron, Ohio 44311

Phone 330.572.2100
www.gpdgroup.com



2020361.01

ADDENDUM NO. 1
to
BIDDING DOCUMENTS
For

YMHA MATTHEWS RENOVATION
Site Package
321 Matthews Road, Youngstown, OH 44512

07-20-20

-
- A. The original bidding documents for the above-referenced project are hereby amended as noted in Addendum No. 1.
- B. This Addendum supersedes and takes precedence over information provided prior to the date of this Addendum.
- C. This Addendum includes:
1. Addendum No. 1 – 1 page.

QUESTIONS

1. We are supposed to include the removal of existing asphalt AND the 6" of existing stone or just the asphalt and grade the existing stone before paving?

Response: The contractor is to remove asphalt and stone base in the areas defined by keynote 2 on sheet C-101. Keynote 8 areas shall be removed to a depth that allows the installation of a new 10" pavement section. The subgrade shall be regraded so that the new 10" section can meet the proposed spot elevations shown on sheet C-121.

END OF ADDENDUM NO. 1